

Progress, a passion to share

LABORATORY IN TRAPPES
29 avenue Roger Hennequin —78197 Trappes Cedex
Tel.: 01 30 69 10 00 — Fax: 01 30 69 12 34

MATERIAL FIRE CLASSIFICATION REPORT

as defined in article 5 of the decree dated 21 November 2002

VALID FOR 5 YEARS from 8 July 2013

N° P107247 - DE/1

and 4 pages in appendices

Material presented by: FILMOLUX SA

300 rue Etienne Marcel 93170 BAGNOLET

Trademark: FILMOLUX® EASY CLEAR GLOSS

Summary description:

Overall composition: PVC film with acrylic adhesive.

Application: Various applications

Mass: $(90 \pm 5) \text{ g/m}^2$ Thickness: $(70 \pm 5) \text{ pm}$ Colouring:Transparent

Testing report: N° P107247 - DE/1 of 8 July 2013

Nature of tests: Radiation test.

Classification: M1 ADHESIVE ON 15/10e mm STEEL SHEET

VALID FOR ANY APPLICATION FOR WHICH THE PRODUCT IS NOT SUBJECT TO CE MARKING

Durability of the classification (NF P 92.512: 1986): UNLIMITED IN PRINCIPLE

taking into account the criteria resulting from the tests described in testing report N° P107247 DE/1 in appendix.

This report states only the characteristics of the sample tested and does not predict the characteristics of similar products. This is not a product certification as defined by article L. 115-27 of the consumer code and the law of 3 June 1994.

Reproduction is permitted only in full of either this Classification report which comprises 1 page or the entire Report and appendix which **comprise 5 pages.**

Trappes, 8 July 2013

Manager of the Energy, Environment and Combustion Department

Noelle LOFERME-PEDESPAN



Performance of testing Olivier LARADE Testing Manager

Emilie COLIN - DENIAU



Accreditation N° 1.0606 Scope available

National laboratory for metrology and testing